



CSA INTERNATIONAL

Pietro Fiorentini USA
P.O. Box 728
Norcross, Georgia 30091

August 4, 2009

RE: CSA Certificate # 2010806, Master Contract # 242437, Project # 2155089

To whom it may concern,

All Pietro Fiorentini Governor Regulators incorporate an integral vent limiter that complies with the provisions of CSA6.22a- 2005 / ANSI Z21.80a – 2005 Line Pressure Regulators, and CSA 6.3 - 200 / ANSI Z21.18 – 2000 Appliance Pressure Regulators standards. CSA has certified that the Governor series of Line Pressure and Appliance regulators as a vent limiting (ventelsss) gas pressure regulator. Therefore, venting of and vent line connections to the Governor series regulators are not needed if acceptable by the authority having regulatory jurisdiction of the installation.

Regards,

Richard Clark
Engineering Technologist
CSA International
416.747.2331