


Submetering & Automatic Meter Reading System Basic Configuration Diagram

Location of Installation:
Number of Metering Points:
Number of Floors:

Note: Meter reads must be **manually** entered into spread sheet



SW running on PC
w: Windows 98,
2000, ME, XP or
NT



Notes:

1. This offer only includes HW , SW and Services as noted in the attached BOM.
2. Wiring diagrams are presented for informational purposes and this quote does NOT include cabling
3. SW and commissioning assistance provided as per attached BOM
4. PC not included.

Description: Meters are utility grade (ANSI B109.1 for Gas and ANSI/AWWA C708 for water) and each have an encoded index. The encoder is wired up to a TouchPad that can be installed in an easy to access area. The meters can be installed out of the way in a utility closet, in a drop ceiling or in each apartment. The TouchPads permit the meters to be read using a Visual Reader, which when touched against a pad will display the meter number and totalized volume without entering the tenants apartment. The total usage is noted and can be entered into a spreadsheet to calculate monthly usage.

FOLLIN FLO ▶ CONTROLS
a division of **BIG WAVE** inc

Rev: 1

AMR Configuration Diagram

FFC Ref: 05020201 -GW